

Preliminary Assessment Report

Project 3019460, 2737 W COMMODORE WAY

Assessment Completed: 1/23/2015

Project Description: The proposed remedial alternative requires excavation of approximately 23,700 cu yds of contaminated soil and backfilling with approximately 23,700 cubic yards of clean soil. The contaminated soil material will be disposed at an approved disposal facility. A small shed on the property will also be removed.

Primary Applicant: [Pam Xander](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Department of Planning and Development (DPD) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with DPD. **Please bring a copy of this report to your intake appointment.**

Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

DPD Drainage Requirements

Arthur Thomas Richardson, (206) 684-3655, art.richardson@seattle.gov

DPD Land Use Requirements

Megan Neuman, (206) 684-3101, Megan.Neuman@Seattle.gov

DPD Preapplication Site Visit Requirements

Douglas Thresher, (206) 233-3875, Douglas.Thresher@seattle.gov

Seattle City Light Requirements

Ray Ramos, (206) 615-1193, ray.ramos@seattle.gov

Seattle Department of Transportation Requirements

Yohannes Minas, (206) 733-9044, yohannes.minas@seattle.gov

Seattle Public Utilities Requirements

Jebessa Dara, Jebessa.Dara@seattle.gov

Water Availability

SPU Staff, (206) 684-3333, SPUWaterAvailability@Seattle.Gov

Other Resources

- General questions about the permit process: Contact the DPD Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [DPD](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

Requirements

DPD Drainage Requirements

The following requirements are based on the current stormwater and side sewer codes.

Existing Public Drainage Infrastructure

Combined sewer main location: 27th Ave W

Combined sewer main size: 8-inch

Other location: W Commodore (Way King Co Metro Line)

Other size: 144-inch

Drainage

The drainage point of discharge (SMC 22.805.020) is located at: Combined sewer. King Co main Commodore /SPU 27th

Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. A completed [Construction Stormwater Control and Soil Amendment Standard Plan](#) is required.

Water Quality

No requirements

Permanent and Temporary Dewatering

Per SMC 21.16.110, the proposed project requires a separate side sewer permit for temporary dewatering based on the following: contaminated surface and/or groundwater.

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following: Combined system.

This project is required to obtain a side sewer permit for temporary dewatering (SSPTD) from DPD prior to issuance of the building permit ([DR 13-2010](#)). Since discharge is to the combined sewer, you must first obtain a discharge authorization letter from King County.

King County Industrial Waste Program
130 Nickerson St. Suite 200
Seattle, WA 98109-1658
206-263-3000

DPD Land Use Code Requirements

Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

W FORT ST

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

W COMMODORE WAY

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

27TH AVE W

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

Land Use

Based on the project scope and/or location of environmentally critical areas on the development site, SEPA may be required. See CAM 208 for more details.

Pre-Application Site Visit (PASV) Requirements

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

ECA Mapping Unit and Type

This project site appears to include the following ECAs and/or buffers:

Steep slope

Potential slide

Fish and wildlife

Earth Disturbance

If excavation has the potential to encroach on adjacent property in order to facilitate construction activity, please provide documentation of consent from the adjacent property owner. Show area of proposed encroachment on the submitted drawings and detailed cross-sections.

If temporary cuts greater than 1h:1v will be required in order to facilitate construction activity, please provide a geotechnical engineer's verification that soil conditions allow cuts to stand unsupported. Include detailed cross sections.

Please show all existing and proposed retaining walls/rockeries and the exposed height.

If shoring will be required, please provide submittals by geotechnical and structural engineers and show the proposed system on the submitted drawings. Include detailed cross sections.

Existing ROW Conditions

W FORT ST

Street conditions:

Concrete paving

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 4" inches

W COMMODORE WAY

Street conditions:

Asphalt paving

Curb conditions:

No curb adjacent to site

A storm inlet is located <350 ft from the site and prior to crossing a public right of way.

27TH AVE W

Street conditions:

Asphalt paving

Curb conditions:

No curb adjacent to site

A storm inlet does not appear to be located <350 ft from the site and prior to crossing a public right of way.

Potential Impacts to Seattle Parks Property

No parks property in vicinity

Tree Protection

Existing trees appear to be shown accurately on the site plan

Construction Stormwater Control

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 16-2009, Volume 2](#)).

Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Place silt-trapping inserts in receiving catch basins located within 10 feet of construction entrance.

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](#) at

<http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

Standard Submittal Requirements for Projects in an ECA

Submit a geotechnical report with the permit intake submittal package. Geotechnical report must be signed and stamped by a geotechnical engineer licensed in the State of Washington per [SMC 22.170.070](#), [SMC 25.09](#), and [Directors Rule \(DR\) 18-2011](#).

Provide a topographic survey with 2-foot contours on and within 25-feet of the property, stamped by a licensed land surveyor (see [25.09.330A](#))

Delineate the clearing limits on the site plan

Provide a vegetation restoration plan per [SMC 25.09.320](#), [Tip 331](#) and [Tip 331A](#). **Prior to any vegetation removal in the critical area, review, approval, and a preconstruction meeting is required**

Delineate the steep slope critical area on a site plan based on the survey (per [SMC 25.09.020 A3b\(5\)](#)).

Provide area calculations for the steep slope delineation.

Show the steep slope buffer. Generally, the buffer is 15-feet from the top and/or toe of the slope

Construction activity area appears to be within the steep slope critical area and/or its associated buffer. A steep slope variance may be required (see [SMC 25.09.180E.1](#))

An ECA pre-submittal conference is strongly recommended. Call the Applicant Services Center (206-684-8850) to schedule an appointment

Site is located within a great blue heron management area. Refer to [Director's Rule 5-2007](#).

Seattle City Light Requirements

Street/Alley Requirements

W FORT ST

Other requirements: There are underground electrical lines and facilities along W Fort St. Before digging contact the Utilities Underground Location Center ("One-Call") at 1-800-424-5555 two business days in advance to locate and mark underground utilities, per State law (RCW 19.122). Underground electrical facilities/conductors require separation from other utilities. Review SCL Construction Guideline U2-10.

W COMMODORE WAY

Working Clearance: State law requires construction workers, their tools, machinery, equipment, and materials to maintain a 10-foot clearance from power lines. Review WAC 296-24-960 and OSHA 1910.333(c)(3)(i). Transmission lines require greater clearance. To work near power lines, notify SCL well in advance to de-energize and ground the lines, or relocate the lines temporarily. This SCL work is done at the project's expense. There are overhead high voltage lines along the north side of W Commodore Way.

Other requirements: There are underground electrical lines that cross W Commodore Way from the north side to the project site. Before digging contact the Utilities Underground Location Center ("One-Call") at 1-800-424-5555 two business days in advance to locate and mark underground utilities, per State law (RCW 19.122). Underground electrical facilities/conductors require separation from other utilities. Review SCL Construction Guideline U2-10.

27TH AVE W

Working Clearance: State law requires construction workers, their tools, machinery, equipment, and materials to maintain a 10-foot clearance from power lines. Review WAC 296-24-960 and OSHA 1910.333(c)(3)(i). Transmission lines require greater clearance. To work near power lines, notify SCL well in advance to de-energize and ground the lines, or relocate the lines temporarily. This SCL work is done at the project's expense. There are overhead high voltage lines along the east side of 27th Ave W.

Notes to Applicant

Please contact your Electrical Service Representative to coordinate electrical disconnections prior to demolition and temporary power for construction if needed. Your Electrical Service Representative is: Tim Harris, 206-615-0115, tim.harris@seattle.gov. Be advised that it is the applicant's responsibility to seek guidance from SCL. Failure to contact SCL early in the permit process could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SDOT Requirements

Based on the information provided at this time, it appears that no street improvements are **required**. All work in the right-of-way requires a permit. Therefore, if you are planning discretionary improvements you should contact SDOT as soon as possible. Be advised that it is the applicant's responsibility to seek guidance from SDOT Street Use should the scope of the project change, or should the applicant become aware of proposed construction in the ROW. Failure to contact SDOT at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SPU Requirements

Water Availability

Your water availability assessment has been approved.
Water Availability Certificate reference number: 20150008
Water Availability Certificate status: Approved with No Changes
Prepared by: Richard F Wilson

Existing Water System Information

Proximity of nearest fire hydrant is: 280 feet NE of property. Meets standards.

Water Main:

Size: 12 inches	Material: Cast Iron	Class: B
- Standard		
- Abutting		

Water Main is available to serve in: W Commodore Way
Distance of main to S margin of street is 62 feet.
Public ROW width is 100 feet.

Water Service(s):

Size: 3/4"	Material: Copper
Size: 6"	Material: Other/unknown
Size: 4"	Material: Ductile Iron
Size: 2"	Material: Copper
Size: 3/4"	Material: Plastic
Size: 3/4"	Material: Plastic
Size: N/A"	Material: Other/unknown

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:
http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf. For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, Liz.Kain@seattle.gov.

Other Requirements

Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your DPD intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our DPD intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, Michale.Crooks@seattle.gov, or visit the [Licensing and Tax Administration Division website](#).